


H2O Head Office		Parts List				
		Project Name:				
		Author:		Emile Berries		
		Date:				
Description:		UF Backup / Added Protection				
General Part Information				Part number	Technical Documents	Supplier
Tag	Part Description	Part Specifications	Quantity			
	20" Big Blue 1" Port DBL oring	BB20 Housing	2	BBB201D		WCSA
	Melt Blown filter	20" BB melt blown filter	1	APPBB20-5		WCSA
	Melt Blown filter	20" BB melt blown filter	1	APPBB20-1		WCSA
	BB20 Bracket	Floorstanding for 2x BB	1	AC10-14		WCSA
	Inside out UF Module	4040 UF Module	1	AQ4040		WCSA
	Pressure Vessel for 4040 Element	300PSI 4040 SS Pressure Vessel	1	BN1-4040		WCSA

All piping and fittings from Polypipe systems/Effast/Natal plastic supplies/PE Plastics if PVC is being used. <http://www.effast.co.za/>
Other option is Copper and conex fittings or welded copper fittings from varies supplies like Plumblink and almost any plumbing store.
NB*** Always make use of unions between vessels and before. This will help when one need to service, change media etc...